

Exhibit D

City of Tucson Amendments to the 2024 International Fuel Gas Code

Chapter 1 Administration. DELETE Chapter 1 with the exception of Sections 101.2.5 and 111. (Deleted sections are administered by ~~2018~~ the 2024 IBC, Chapter 1)

Section 404.17.3 Tracer. REVISE Section to state: A yellow insulated copper tracer wire or other *approved* conductor, or a product specifically designed for that purpose, shall be installed adjacent to underground nonmetallic *piping*. *Access* shall be provided to the tracer wire or the tracer wire shall terminate a minimum of 12 inches above ground at each end of the nonmetallic *piping* *securely attached at both ends*. The tracer wire size shall be not less than 18 AWG and the insulation type shall be suitable for direct burial.